

GURUGRAM

To M/s Suncity World School

Sector 54, Gurugram

Memo No. FS/2020/1094 dated : 15/09/2020

Subject: Renewal of No Objection Certificate 15 mtrs. and Above height from the fire Safety Point of View of the Group B-Educational Building at Sector 54, Gurugram of M/s Suncity World School :

Reference to you online No 050262023002627 dated 28/08/2020 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
SPA Block	Ground Floor	7.00 Mt.	334.00 Sq. Mt.
High School	G to 03	13.20 Mt.	4545.625 Sq. Mt.
Primary School	G to 03	15.20 Mt.	1075.174 Sq. Mt.
Basement Level	Basement Area	Remarks	
Basement- 01	318.82 Sq. Mt.	SPA Block	

Your site for the Renewal of the Fire NOC has been inspected by the Team of Fire Station Officers, GURUGRAM from fire safety Point of View. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines.

In view of the satisfactory fire protection system / arrangement mentioned as above, this office has no objection for occupation from the Fire Safety point of view, with the following conditions:-

- 1) The owner/occupier shall keep duly trained Fire Staff in all three shifts.
- 2) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 3) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
- 4) You are directed to apply for Renewal of NOC in future before 2 month of expiry of your NOC.
- 5) The open set back area is not checked at our end as it shall be checked by concerned building department.
- 6) The owner/occupier shall strictly follow the other applicable rules/ regulations/ byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per fire ordinance 2009 specially chapter- III Section 31 Sub-Section 1 & 2 of Fire Act 2009.
- 7) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Officials/Residents/R.W.A. should be mentioned in the drill.
- 8) If the Infringements of Byelaws remains un- noticed the Authority reserves the right to amend the NOC as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.

The above Renewal of NOC is valid for **One** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- HR 1000



**SUNCITY SCHOOL**  
(Suncity Township, Sec-54, Gurgaon)

Administrator

Self Attested  
10/2/2021

ADFO

GURUGRAM

Exercising the power of Director, Fire Services, Haryana



Digitally signed by SATYAVAN SINGH  
Date: 2020.09.15 14:04:23 +05:30  
Reason: Digital Verification

From ASSISTANT DIVISIONAL FIRE OFFICER, GURUGRAM  
GURUGRAM

From Director General  
Fire Service, Haryana Panchkula  
To M/s Uddar Gagan Properties Pvt Ltd  
Sector 54, Gurugram  
Memo No. FS/2019/111 dated : 13/05/2019

Subject : No objection Certificate 15 mtrs. and Above from the fire safety point of view for Group B- Educational Building at Sector 54, Gurugram of M/s Uddar Gagan Properties Pvt Ltd :

Reference your letter no. 050261923001198 dated 26/03/2019 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
01	G to 04	16.95 Mt.	262.826 Sq. Mt.
Tower Name	Basement Level	Basement Area	Basement Remarks
Nil	Nil	Nil	Nil

- 1) The owner/occupier shall give a self declaration certificate annually regarding fire safety system installed in his building/premises is working in good condition and there is no addition/alteration in the building.
- 2) In case there is any addition/alteration in the building, the fire NOC shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme
- 3) As per sub-section (1) and the competent authority may randomly check such building/premises.
- 4) The owner/occupier shall keep duly trained Fire Staff in all three shifts.
- 5) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 6) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
- 7) You are directed to apply for NOC in future before 2 months of expiry of your NOC.
- 8) The open set back area is not checked at our end as it shall be checked by concerned building authority/department.
- 9) The owner/occupier shall strictly follow the other applicable rules/ regulations/ byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Fire Act 2009 specially chapter- III Section 31 Sub-Section 1 & 2 of Fire Act 2009.
- 10) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Official/Staff should be participated in the drill.
- 11) If the Infringements of Byelaws remains un-noticed the Authority reserves the right to amend the NOC as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 2) NOC granted subject to condition that there is no violation in sanctioned building plan by virtue of which fire fighting scheme was approved

The above NOC is valid for only **Five** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- Application Updated



SCHC  
(Municipality Township, Sec-54, Gurugram)  
K. Anil Kumar

Deputy Director (Technical)-I,  
for Director General, Fire  
Service, Haryana  
Panchkula

Exercising the power of Director, Fire Services, Haryana



# Government of Haryana

Acknowledgement

SARAL ID : FNOC/2021/02608

Receipt Date : 25/08/2021

Department Name:

Department of Urban Local Bodies

Service Name:

Issue of Fresh / Revised Fire NOC

Name:

Sushil Sharma

Mobile No:

9354767811

Email ID:

sushilsharma8447@gmail.com

Permanent Address:

Suncity Township Sector 54 Gurgaon

Thank you for using SARAL!

Please Note:

**How can I track status?**


**How will I know that my application has been processed?**

**From where can I download the output certificate?**

Enter your SARAL ID in the "Track Your Application" feature on the homepage.

You will receive a notification from the department through SMS.

Visit <https://online.ulbharyana.gov.in/> and download the certificate using SARAL ID.



Open Government Data (OGD) Platform India



india



DeitY



Site is technically designed, hosted and maintained by National Informatics Centre  
Contents on this website is owned, updated and managed by the Ministry of Panchayati Raj

POWERED BY SERVICEPLUS